



Telephone::0485-2998170
email:-qcsdlmvpa@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, MUVATTUPUZHA 686673
WATER TEST-BACTERIOLOGY REPORT

Report No: MVPA/4404/6/23

Report of Issue Date: 09.06.2023

Customer Name & Address Nirmala Public School Muvattupuzha	Date of Receipt of Payment	31.05.2023	
	Date of Sample received	05.06.2023	
	Sample given by	Customer	
	Sample Code	4404/6/23	
	Sample Name	Water	
	Sample Condition	Good	
	Source of Sample	Open Well	
	Sample Quantity	250 ml	
Test performing dates : From: 07.06.2023 To 08.06.2023			
Sl. No.	Source	Coliforms per 100ml of sample	E Coli in 100 ml of sample
1	Water sample submitted by the customer	More than 100 CFU/ 100 ML	4 CFU/ 100 ML

Remarks:-

- NB:-1) The result stated above related only to the sample(s) submitted for testing by the Customer .
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed By

Sheeja K

Authorized By

Anju

Technical Manger Sheeja K

Quality Manager Anju Anto

KWA/QCSDL/MVPA/F-26

Issue Date : 02.07.2021

No:01

Rev.Date :-01.03.2023

Page 1 of 1

End of Report



QUALITY MANAGER
KWA, QCSDL
MUVATTUPUZHA